


Water T&D Construction Standard

2" METER SETTING - COMPOUND METER

APPLICATION; Commercial and Industrial water metering.



** Allows room for two 1/8" thick gaskets

INSTALLATION NOTES

- Customers plumbing shall include a shut off valve on the outlet side of the meter setting or the water meter will not be installed by LBWL.
- Meter shall be installed by LBWL personnel only.
- Sending wire and touch pad shall be installed per LBWL Standard W-04-0011.
- Supports are required for all meter installations. Supports shall be made from non-corrosive materials.
- A Pipe section preceeding the meter must be a minimum of 20" in length in order to provide undisturbed flow of water for accurate metering. Lengths greater than 20" are desirable when area for meter installation allows.
- (B) Inlet valve shall be locked in the closed position if no meter is to be installed in the meter setting.

MATERIALS FOR 2" COMPOUND METER SETTING				
REF	ITEM NO.	QTY*	DESCRIPTION	
1	30-45402	As Req'd	Tube, Copper Type K, 2" x 20ft.	
2	_30-26887	1	Coupling, 2" CTS Comp x 2" M.I.P.	
3	30-70608	1	Valve, Ball, Straight, 2" Meter FLG x F.I.P.	
4	30-14572	1	Meter, 2" Compound	
5	30-29239	1	Flange, 2" Meter x F.I.P.	
6	30-37111	2	Bolt and gasket set, 2" flanged meter	
7	30-09505	1	Meter Support, adjustable	
* Required for one complete setting				

Page	1 of 1
Director of Engineering	Date: 8/30/06
Director of Delivery Mala Delivery	Date: 9/5/01