

4/2021


W-02-1660



WATER T&D Construction Standard

SOLID SLEEVE ASSEMBLY 4" THROUGH 12"

APPLICATION: Installation of Solid Sleeve for a connection between an existing Iron Pipe and a new Ductile Iron Pipe.



INSTALLATION NOTES:

- For sleeve installation larger than 12" contact LBWL Engineer for restraint requirements.
- The new ductile iron pipe is to be restrained according to Water T&D Construction Standard W-02-0100.
- Completed assembly to be poly wrapped.

MATERIALS 4"				MATERIALS 6"			
REF	ITEM NO.	QTY	DESCRIPTION	REF	ITEM NO.	QTY	DESCRIPTION
1	36-31708	1	SLEEVE, SOLID 4" MJ LONG, STANDARD	1	36-31708	1	SLEEVE, SOLID 6" MJ LONG, STANDARD
2	36-23516 OR 36-23727	2	GLAND, RETAINER, WEDGE, 04" OR GLAND, RETAINER, WEDGE, 4" OS	2	36-23529 OR 36-23730	2	GLAND, RETAINER, WEDGE, 06" OR GLAND, RETAINER, WEDGE, 6" OS

MATERIALS 8"				MATERIALS 12"			
REF	ITEM NO.	QTY	DESCRIPTION	REF	ITEM NO.	QTY	DESCRIPTION
1	36-31708	1	SLEEVE, SOLID 8" MJ LONG, STANDARD	1	36-31708	1	SLEEVE, SOLID 12" MJ LONG, STANDARD
2	36-23532 OR 36-23743	2	GLAND, RETAINER, WEDGE, 08" OR GLAND, RETAINER, WEDGE, 8" OS	2	36-23558 OR 36-23769	2	GLAND, RETAINER, WEDGE, 12" OR GLAND, RETAINER, WEDGE, 12" OS

1 of 1

Manager, Water & Steam Distribution *Todd Russell*

Date: 2/9/2022

Director of Water Operations *Sanjeev Munjarwadi*

Date: 2/10/2022